

Morris, John

---

From: Henderson, Stuart  
Sent: 07 September 2011 16:13  
To: adm1dmbcorr  
Subject: P/11/0506/FUL/ONLINE  
**ENVIRONMENTAL HEALTH**

Noise need not be considered as a determining factor in considering this application.

Informative - The builder shall ensure that noisy work which is audible at the site boundary shall ONLY be conducted between the following hours:  
Monday to Friday 08:00 - 18:00 Hours  
Saturday 09:00 - 17:00 Hours  
Sunday / Bank Holidays 10:00 - 16:00 Hours  
Deviation from these hours of work is not permitted unless in emergency circumstances and with the prior approval of the Environmental Health Manager.

**CONTAMINATED LAND**

Our records indicate that there is an infilled water line/ culverted burn running through the southern section of the proposed planning application.

In the event that unexpected contamination is encountered following the commencement of development, all work on the affected part of the site shall cease. The developer shall notify the Planning Authority immediately, carry out a contaminated land assessment and undertake any necessary remediation works. Development shall not recommence without the prior written approval of the Planning Authority

Stuart Henderson  
Environmental Health Officer  
Falkirk Council  
01324 504771

---

\*\*\*\*\*  
The information contained in this e-mail is confidential and is intended only for the named recipient(s). If you are not the intended recipient, you must not copy, distribute or take any action or reliance on it. If you have received this e-mail in error, please notify the sender. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited.

The views and opinions expressed in this e-mail are the senders own and do not necessarily represent the views and opinions of Falkirk Council.  
\*\*\*\*\*