

**John Morris**

---

**From:** Agnew, Sharon  
**Sent:** 01 March 2019 11:47  
**To:** Paterson, David  
**Subject:** RE: Bo'ness site.

David,

Further to our earlier discussion, the applicant will be required to submit a drainage strategy for this site. Due to the location and topography of the site overland flow from the fields to the south have the potential to flood the site. Properties to the west are protected by a ditch for this reason, this however does not appear to extend far enough eastwards to protect the site, consideration to installing drainage to mitigate flood risk on the southern boundary should be given.

Hope this helps

Regards

Sharon

---

**From:** Paterson, David  
**Sent:** 01 March 2019 10:58  
**To:** Agnew, Sharon  
**Subject:** Bo'ness site.

Hello Sharon

Sorry for this. The app number is P/18/0384/PPP.

Ta

David Paterson  
Development Management Officer  
Falkirk Council  
Development Services  
Abbotsford House  
Falkirk  
FK2 7YZ

Tel: 01324 504757

The link below is for the Development Management Survey which we would be grateful if you would complete and submit.

<https://say.falkirk.gov.uk/development-services/16ef7d28/>

For information, the undernoted is the direct link to the Scottish Government eplanning website  
<https://eplanning.scotland.gov.uk/WAM>

# make it happen

## council of the future

---

\*\*\*\*\*

The information contained in this e-mail is confidential and is intended only for the named recipient(s). If you are not the intended recipient, you must not copy, distribute or take any action or reliance on it. If you have received this e-mail in error, please notify the sender. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited.

The views and opinions expressed in this e-mail are the senders own and do not necessarily represent the views and opinions of Falkirk Council.

\*\*\*\*\*